



**NOTE FLOOR REQUIREMENTS**  
 FOR PROPER ANCHOR EMBANKMENT  
 FLOOR MUST BE A MINIMUM OF  
 4,000 PSI REINFORCED CONCRETE  
 AT 6.00 IN. THICK